





大分県_出来形フォーマットサンプル

測定者

印




出来形管理図（ヒストグラム）

管理種別盛土工（管理）

管理特性

測定者




管理位置	基準高 L		基準高 C		基準高 R		道路幅 w		左法長1 L-11	
	値 (+)	値 (-)	値 (+)	値 (-)	値 (+)	値 (-)	値 (+)	値 (-)	値 (+)	値 (-)
規格値	+50	-50	+50	-50	+50	-50		-100		-100
規格値 80%	+40.0	-40.0	+40.0	-40.0	+40.0	-40.0		-80.0		-80.0
規格値 50%	+25.0	-25.0	+25.0	-25.0	+25.0	-25.0		-50.0		-50.0
	個数	%	個数	%	個数	%	個数	%	個数	%
±0	8	100.0 %	8	100.0 %	8	100.0 %	8	100.0 %	7	87.5 %
上限規格値外	0	0.0 %	0	0.0 %	0	0.0 %		%		%
下限規格値外	0	0.0 %	0	0.0 %	0	0.0 %	0	0.0 %	0	0.0 %
最大値		0		0		0		0		0
最小値		0		0		0		0		-1
測点総数		8		8		8		8		8

出来形管理図

管理種別 盛土工 (管理)

管理特性 測定者 印




管理位置			基準高 L			管理位置			基準高 C			管理位置			基準高 R			管理位置			道路幅 w			管理位置			左法長1 L-I1		
規格値			±50			規格値			±50			規格値			±50			規格値			-100			規格値			-100		
測点 又は 区別	設計値	測定値	設計値 との差	測点 又は 区別	設計値	測定値	設計値 との差	測点 又は 区別	設計値	測定値	設計値 との差	測点 又は 区別	設計値	測定値	設計値 との差	測点 又は 区別	設計値	測定値	設計値 との差	測点 又は 区別	設計値	測定値	設計値 との差	測点 又は 区別	設計値	測定値	設計値 との差		
	No. 0	1.960	1.960		±0	No. 0	2.000		2.000	±0	No. 0		1.960	1.960	±0		No. 0	4.000	4.000		±0	No. 0	3.606		3.606	±0	No. 0	3.606	3.606
No. 1	1.560	1.560	±0	No. 1	1.600	1.600	±0	No. 1	1.560	1.560	±0	No. 1	4.000	4.000	±0	No. 1	3.606	3.606	±0	No. 1	3.606	3.606	±0	No. 1	3.606	3.606	±0		
No. 1+19.950	1.161	1.161	±0	No. 1+19.950	1.201	1.201	±0	No. 1+19.950	1.161	1.161	±0	No. 1+19.950	4.000	4.000	±0	No. 1+19.950	3.606	3.606	±0	No. 1+19.950	3.606	3.606	±0	No. 1+19.950	3.606	3.606	±0		
No. 2	1.160	1.160	±0	No. 2	1.200	1.200	±0	No. 2	1.160	1.160	±0	No. 2	4.000	4.000	±0	No. 2	3.606	3.606	±0	No. 2	3.606	3.606	±0	No. 2	3.606	3.606	±0		
No. 2+4.741	1.055	1.055	±0	No. 2+4.741	1.105	1.105	±0	No. 2+4.741	1.145	1.145	±0	No. 2+4.741	4.500	4.500	±0	No. 2+4.741	3.606	3.606	±0	No. 2+4.741	3.606	3.606	±0	No. 2+4.741	3.606	3.606	±0		
No. 2+19.491	0.770	0.770	±0	No. 2+19.491	0.820	0.820	±0	No. 2+19.491	0.860	0.860	±0	No. 2+19.491	4.500	4.500	±0	No. 2+19.491	3.606	3.605	-1	No. 2+19.491	3.606	3.605	-1	No. 2+19.491	3.606	3.605	-1		
No. 3	0.763	0.763	±0	No. 3	0.813	0.813	±0	No. 3	0.853	0.853	±0	No. 3	4.500	4.500	±0	No. 3	3.606	3.606	±0	No. 3	3.606	3.606	±0	No. 3	3.606	3.606	±0		
No. 3+4.282	0.717	0.717	±0	No. 3+4.282	0.757	0.757	±0	No. 3+4.282	0.797	0.797	±0	No. 3+4.282	4.000	4.000	±0	No. 3+4.282	3.606	3.606	±0	No. 3+4.282	3.606	3.606	±0	No. 3+4.282	3.606	3.606	±0		
No. 4	0.673			No. 4	0.713			No. 4	0.673			No. 4	4.000			No. 4	3.606			No. 4	3.606			No. 4	3.606				
No. 4+6.335	0.725			No. 4+6.335	0.765			No. 4+6.335	0.725			No. 4+6.335	4.000			No. 4+6.335	3.606			No. 4+6.335	3.606			No. 4+6.335	3.606				

出来形管理図

管理種別 盛土工 (管理)

管理特性 測定者 印



管理位置	基準高 L			管理位置	基準高 C			管理位置	基準高 R			管理位置	道路幅 w			管理位置	左法長1 L-I1		
規格値	±50			規格値	±50			規格値	±50			規格値	-100			規格値	-100		
測点 又は区別	設計値	測定値	設計値との差	測点 又は区別	設計値	測定値	設計値との差	測点 又は区別	設計値	測定値	設計値との差	測点 又は区別	設計値	測定値	設計値との差	測点 又は区別	設計値	測定値	設計値との差
No. 0	1.960	1.960	±0	No. 0	2.000	2.000	±0	No. 0	1.960	1.960	±0	No. 0	4.000	4.000	±0	No. 0	3.606	3.606	±0
No. 1	1.560	1.560	±0	No. 1	1.600	1.600	±0	No. 1	1.560	1.560	±0	No. 1	4.000	4.000	±0	No. 1	3.606	3.606	±0
No. 1+19.950	1.161	1.161	±0	No. 1+19.950	1.201	1.201	±0	No. 1+19.950	1.161	1.161	±0	No. 1+19.950	4.000	4.000	±0	No. 1+19.950	3.606	3.606	±0
No. 2	1.160	1.160	±0	No. 2	1.200	1.200	±0	No. 2	1.160	1.160	±0	No. 2	4.000	4.000	±0	No. 2	3.606	3.606	±0
No. 2+4.741	1.055	1.055	±0	No. 2+4.741	1.105	1.105	±0	No. 2+4.741	1.145	1.145	±0	No. 2+4.741	4.500	4.500	±0	No. 2+4.741	3.606	3.606	±0
No. 2+19.491	0.770	0.770	±0	No. 2+19.491	0.820	0.820	±0	No. 2+19.491	0.860	0.860	±0	No. 2+19.491	4.500	4.500	±0	No. 2+19.491	3.606	3.605	-1
No. 3	0.763	0.763	±0	No. 3	0.813	0.813	±0	No. 3	0.853	0.853	±0	No. 3	4.500	4.500	±0	No. 3	3.606	3.606	±0
No. 3+4.282	0.717	0.717	±0	No. 3+4.282	0.757	0.757	±0	No. 3+4.282	0.797	0.797	±0	No. 3+4.282	4.000	4.000	±0	No. 3+4.282	3.606	3.606	±0
No. 4	0.673			No. 4	0.713			No. 4	0.673			No. 4	4.000			No. 4	3.606		
No. 4+6.335	0.725			No. 4+6.335	0.765			No. 4+6.335	0.725			No. 4+6.335	4.000			No. 4+6.335	3.606		
No. 4+11.335	0.874			No. 4+11.335	0.834			No. 4+11.335	0.784			No. 4+11.335	4.500			No. 4+11.335	3.606		
No. 5	1.040			No. 5	1.000			No. 5	0.950			No. 5	4.500			No. 5	3.606		
No. 5+5.876	1.158			No. 5+5.876	1.118			No. 5+5.876	1.068			No. 5+5.876	4.500			No. 5+5.876	3.606		
No. 5+10.876	1.178			No. 5+10.876	1.218			No. 5+10.876	1.178			No. 5+10.876	4.000			No. 5+10.876	3.606		
No. 6	1.360			No. 6	1.400			No. 6	1.360			No. 6	4.000			No. 6	3.606		

出 来 形 管 理 図 表

管理特性

測定者

印

種 別				種 別				種 別				種 別				種 別			
基準高				基準高				基準高				道路幅				左法長1			
規格値				規格値				規格値				規格値				規格値			
±50				±50				±50				-100				-100			
測 点 又は区分	設計値	測定値	設計値 との差	測 点 又は区分	設計値	測定値	設計値 との差	測 点 又は区分	設計値	測定値	設計値 との差	測 点 又は区分	設計値	測定値	設計値 との差	測 点 又は区分	設計値	測定値	設計値 との差
No. 0				No. 0				No. 0				No. 0				No. 0			
	1.960	1.960	0		2.000	2.000	0		1.960	1.960	0		4,000	4,000	0		3.606	3.606	0
No. 1				No. 1				No. 1				No. 1				No. 1			
	1.560	1.560	0		1.600	1.600	0		1.560	1.560	0		4,000	4,000	0		3.606	3.606	0
No. 1+19. 950				No. 1+19. 950				No. 1+19. 950				No. 1+19. 950				No. 1+19. 950			
	1.161	1.161	0		1.201	1.201	0		1.161	1.161	0		4,000	4,000	0		3.606	3.606	0
No. 2				No. 2				No. 2				No. 2				No. 2			
	1.160	1.160	0		1.200	1.200	0		1.160	1.160	0		4,000	4,000	0		3.606	3.606	0
No. 2+4.7 41				No. 2+4.7 41				No. 2+4.7 41				No. 2+4.7 41				No. 2+4.7 41			
	1.055	1.055	0		1.105	1.105	0		1.145	1.145	0		4,500	4,500	0		3.606	3.606	0
No. 2+19. 491				No. 2+19. 491				No. 2+19. 491				No. 2+19. 491				No. 2+19. 491			
	0.770	0.770	0		0.820	0.820	0		0.860	0.860	0		4,500	4,500	0		3.606	3.605	-1
No. 3				No. 3				No. 3				No. 3				No. 3			
	0.763	0.763	0		0.813	0.813	0		0.853	0.853	0		4,500	4,500	0		3.606	3.606	0
No. 3+4.2 82				No. 3+4.2 82				No. 3+4.2 82				No. 3+4.2 82				No. 3+4.2 82			
	0.717	0.717	0		0.757	0.757	0		0.797	0.797	0		4,000	4,000	0		3.606	3.606	0
No. 4				No. 4				No. 4				No. 4				No. 4			
	0.673				0.713				0.673				4,000				3.606		
No. 4+6.3 35				No. 4+6.3 35				No. 4+6.3 35				No. 4+6.3 35				No. 4+6.3 35			
	0.725				0.765				0.725				4,000				3.606		
No. 4+11. 335				No. 4+11. 335				No. 4+11. 335				No. 4+11. 335				No. 4+11. 335			
	0.874				0.834				0.784				4,500				3.606		
No. 5				No. 5				No. 5				No. 5				No. 5			
	1.040				1.000				0.950				4,500				3.606		
No. 5+5.8 76				No. 5+5.8 76				No. 5+5.8 76				No. 5+5.8 76				No. 5+5.8 76			
	1.158				1.118				1.068				4,500				3.606		
No. 5+10. 876				No. 5+10. 876				No. 5+10. 876				No. 5+10. 876				No. 5+10. 876			
	1.178				1.218				1.178				4,000				3.606		
No. 6				No. 6				No. 6				No. 6				No. 6			
	1.360				1.400				1.360				4,000				3.606		
No. 7				No. 7				No. 7				No. 7				No. 7			
	1.760				1.800				1.760				4,000				3.606		

備考 1) 延長を管理するすべてについて使用する。


2) 縦横勾配が大きい時又曲線部は斜長あるいは弦長、弧長等を()書で表わす。

出来形管理図表

管理種別 盛土工（管理） 曲線

測定者

出来形管理図



IP No.	測 点	偏 倚 角		設 計 値 と の 差
		設 計 値	測 定 値	
設 計 値	No. 0			
	No. 1	1.960	1.960	0
	No. 1+19.950	1.560	1.560	0
	No. 2	1.161	1.161	0
	No. 2+4.741	1.160	1.160	0
	No. 2+19.491	1.055	1.055	0
	No. 3	0.770	0.770	0
測 定 値	No. 3	0.763	0.763	0
	No. 3+4.282	0.717	0.717	0
	No. 4	0.673		
	No. 4+6.335	0.725		
	No. 4+11.335	0.874		
	No. 5			

IP No.	測 点	偏 倚 角		設 計 値 と の 差
		設 計 値	測 定 値	
設 計 値	No. 0			
	No. 1	2.000	2.000	0
	No. 1+19.950	1.600	1.600	0
	No. 2	1.201	1.201	0
	No. 2+4.741	1.200	1.200	0
	No. 2+19.491	1.105	1.105	0
	No. 3	0.820	0.820	0
測 定 値	No. 3	0.813	0.813	0
	No. 3+4.282	0.757	0.757	0
	No. 4	0.713		
	No. 4+6.335	0.765		
	No. 4+11.335	0.834		
No. 5				

